

CITY OF DUNSMUIR



"Home of the Best Water on Earth"

November 1, 2017

Appendix 2: PUBLIC NOTIFICATION TEMPLATE
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Tradúzcalo o hable con alguien que lo entienda bien.

Violation of Monthly Coliform Bacteria Standards for September - City of Dunsmuir Public Water System

We routinely monitor for drinking water contaminants including coliform bacteria on a monthly basis and exceeded the coliform bacteria standard for September 2017. In September 2017, two of the four routine water samples tested positive for total coliform bacteria, and four of the five follow-up samples tested positive for total coliform bacteria. The standard is that no more than one sample per month test positive for coliform bacteria. Although this regulatory violation does not constitute an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

Usually, coliform bacteria are a sign that there could be a problem with our source water or the distribution system (pipes and tanks). Whenever we detect coliform bacteria in any sample, we are required to do follow-up testing and check for the presence of other bacteria of greater concern, such as fecal coliform or E. coli. **We did NOT find any fecal coliform or E.coli bacteria in any of the water samples taken from the City of Dunsmuir drinking water system.**

What should you do?

You do not need to boil your water or take other corrective actions.

This is not an emergency. Total coliform bacteria are generally not harmful. *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that there may be leaks, openings, or pathways into the water system.*

People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1 (800) 426-4791.

What Happened? What Was Done?

The origin of the coliform is not known at this time. When the city was notified that coliform was present in a routine sample, the city took action to inspect and flush the water system. There were no problems found during the inspection and a follow up sample was collected at the same location. The sample came back free of coliform bacteria.

The California Division of Drinking Water has issued a citation to the City of Dunsmuir for the violation mentioned above. The citation may be viewed at the following web address:

http://www.waterboards.ca.gov/drinking_water/programs/EnforcementActionsSiskiyou.shtml

Persons wishing more information should contact the City of Dunsmuir at **530-235-4822**

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.